



**CITY MUNICIPAL COUNCIL JAMKHANDI.**

Website: [www.jamkhandicity.mar.gov.in](http://www.jamkhandicity.mar.gov.in)

e-mail ID: [jtstaff\\_ulb\\_jamkhandi@yahoo.co.in](mailto:jtstaff_ulb_jamkhandi@yahoo.co.in)

S.No/CMC/JKD/H.S/2023-24

Date: 26-03-2024

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

It is Certified that an inspection team headed by Subhas I. Chougala J.E, and V.M.Vandal Sr. Health Inspector from Urban Local Body / PHED Inspected the B.L.D.E. Association's Public School Jamkhandi on 19<sup>th</sup> March 2024 and on the basis of Water Test Report (Attached) bearing no MDL22MAY01 dated:26-03-2024 of Chemist Sub-Division Laboratory R.O.W & Sub Division Jamkhandi 587301 certified that the B.L.D.E. Association's Public School Jamkhandi has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

This Certificate is valid till - 25-03-2025

  
Municipal Commissioner  
CMC Jamkhandi  


To  
The Principal  
B. L. D. E. Association's  
Public School Jamkhandi

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies





**RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK**  
**RURAL WATER SUPPLY & SANITATION SUB- DIVISION LABORATORY**  
Sharada Colony, Before GLBC, Jamkhandi-587301  
e-mail:rdwsd.wqmsspjamkhandilab@gmail.com

**TEST REPORT**

Location : B.L.D.E. Association's Habitation: Public School Jamkhandi Village : Jamkhandi G P : Jamkhandi Taluka : Jamkhandi District : Bagalkot			Report date	:	27-03-2024
			Report Number	:	JKDMARCH015
			Reference	:	Sample receipt Form
			Sample receipt date	:	26-03-2024
			Sample code	:	JKD2024MAR0015
			Date of Sample Collection	:	26-03-2024
			Analysis start date	:	27-03-2024
			Analysis completion date	:	27-03-2024
			Sample collection protocol	:	APHA Method
Sample Particulars:	BW	Sample quantity	:	1000ml	
Sl.No	Test	Results	Acceptable Limit is 10500 :2012	Permissible Limit is 10500 :2012 RA:2018	Protocol
1	pH Value @Temp 25±2°C	7.88	6.5-8.5	No Relaxation	IS 3025 (part-11) :2022
2	Specific Conductance, µS/cm @Temp 25±2°C	1451	-	-	IS 3025 (part-14) :2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (part-5&6) :2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (part-8) :2023
5	Colour, Hazen Units	<5	5	15	IS 3025 (part-4) :2021
6	Turbidity, NTU	0.1	1	5	IS 3025 (part-10) :2023
7	Total Dissolved Solids, @180mg/l	832	500	2000	IS 3025 (part-16) :2023
8	Alkalinity as CaCO <sub>3</sub> ,mg/l	194.21	200	600	IS 3025 (part-23) :2023
9	Total hardness as CaCO <sub>3</sub> ,mg/l	341.67	200	600	IS 3025 (part-21) :2009
10	Calcium as Ca,mg/l	65.98	75	200	IS 3025 (part-40) :1991
11	Magnesium as Mg,mg/l	42.98	30	100	IS 3025 (part-46) :2023
12	Chloride as Cl,mg/l	189.66	250	1000	IS 3025 (part-32) :1988
13	Sulphate as SO <sub>4</sub> ,mg/l	68	200	400	IS 3025 (part-24, Sec.1) :2022 Method.a
14	Fluoride as F,mg/l	0.70	1	1.5	APHA 23rd Edition
15	Nitrate as NO <sub>3</sub> ,mg/l	6.83	45	No Relaxation	APHA 23rd Edition
16	Iron as Fe,mg/l	0.25	1	No Relaxation	IS 3025 (part-53) :2003 Method.a
Remarks: The given sample conforms to the Permissible limits of IS:10500:2012 RA2018 Drinking water specification for above tested physical & Chemical parameters only.					

Analysed By: Santosh S Rebial  
Analyst

Authorised Signatory: J P Shetty  
Assistant Executive Engineer

RDWSD/WQMSP/TeR/1

**Note:**

- 1) The above results relates only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) The Traceability : Traceability of measurements is established using CRM's traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in the RDWSD/WQMSP/DR-01.
- 6) Sample brought by the customer

